



**Vadodara Gas Limited**

**Replies to Bidder's Queries & Extension of Bid Submission Due Date**

**Tender No.: VGL/CO/C&P-PNG/BD202304S004 DATED 29/04/2023 & Tender ID: 589430**

**Subject: Hiring the Services for Providing the above Ground GI Installation Including Last Mile at Consumer End for New Domestic PNG Connection**

With reference to the above subject tender, replies to bidder's queries have been addressed below: 004

Sl. No.	Section No.	Page No.	Clause No.	Subjects	Bidder's Query	VGL's Reply
1	SOR	229	G.1.2.1	Individual Connection (up to 10 m 1/2" GI Pipe) 1/2" NB GI pipes from Main isolation valves to appliance valve for individual Apartment connection	The GI pipe connected to the building tapping connection should have a limit of 5 meters GI pipe. In other CGD, the pipe used for tapping connection has a limit of 5 meters GI pipe but the VGL limit is 10 mtr. So please revise tapping connection GI pipe limit.	Ok Noted. Please Refer: Individual Connection (up to 07 m 1/2" GI Pipe) 1/2" NB GI pipes from Main isolation valves to appliance valve for individual Apartment connection
2	SOR	229	G.1.3.2	Installation of 1/2" Riser beyond G+3 floors for each floor extension	It is for beyond G+3 floors or for beyond G+ 3 floors Please Clarify	Please Refer: It is for Installation of 1/2" Riser beyond G+8 floors for each floor extension
3	SOR	230	G.1.6	Additional point in Kitchen with Owner supplied Appliance Valve & Rubber Hose	GI Pipe limit not clearly for kitchen extra point.	Tender Conditions Prevail
4	SOR	230	G.1.11	Installation of GI pipe NB 1/2" per meter The above will only be considered after calculation of total extra GI Pipe. i.e. as per the following formula 1. (15 * No. of Connections – Total GI Pipe used for all connections) and 2. (10 * No. of Geyser Points – Total GI Pipe used for all Geyser Points)	Please clarify calculation of GI pipe	Please Refer: Installation of GI Pipe NB 1/2" per meter, this additional GI Pipe will only be Considered beyond the below provide individual length per connection Applicable extra GI Pipe will be i) For Bungalow connection Beyond – 10 mtr. ii) For Apartment connection Beyond – 07 mtr.
5	Vendors	-	-	Approved Recommended Vendors D-PNG S004	Update new vendor list	Tender Conditions Prevail If any other party for materials or on described to be considered, the contractor has to take prior approval from department.

**Note: This Replies to Bidder's Queries as uploaded on n-Procure & VGL's Website. Please submit the same duly Sign and Seal & to be submitted with Techno-Commercial Bid as this is an Integral Part of the Tender.**